

Result Summary - Overall

Anchorage Design

Code=ACI 318-19

Result Summary - Overall

geometries & weld limitations = **PASS**

limit states max ratio = **0.50 PASS**

Vertical Vessel Leg Anchor


geometries & weld limitations = **PASS**

limit states max ratio = **0.50 PASS**

Sketch

Anchorage Design

Code=ACI 318-19



Vertical Vessel Anchor Forces Calculation

Design Basis and Assumptions

The design of circular pattern anchor bolt group uses the [Method 2 Sawcut with \$h_{ef}'\$ and Neutral Axis at Center](#) as stated in the following references


1. ASCE Anchorage Design for Petrochemical Facilities - 2013 Example 2 Step 5(c) on Page 145
 2. ASCE 2010 Structural Congress - Concrete Breakout Strength in Tension for Vertical Vessel Anchorage in Octagon Pedestals
- The design of circular pattern anchor bolt group is simplified as design of a single anchor bolt with 3 side free edges sawcut at midway between adjacent anchors. The simplified design method uses the following assumptions

1. The moment is resisted only by the anchor bolt group and it does not take into account the contribution of concrete compression force against base plate in the moment equilibrium
2. The neutral axis is not shifted and is located at center of vessel
3. It does not consider strain compatibility between the concrete and steel elements which comprise the anchorage.
4. In the assumed 3 side free edges sawcut model, when anchor is located less than $1.5h_{ef}'$ from three or more edges, the reduced h_{ef}' is used to calculate concrete projected failure area A_{NC}

The utilization ratio of simplified method used in this calculation is conservative compared to the accurate but more complex approach. The detail comparison and analysis of this simplified method is addressed in reference 2 above.

Octagon Concrete Mat Geometrics

Octagon mat face-to-face distance	$D_p =$ from user input	= 196.85 [in]
Anchor bolt bolt circle diameter	$D_{bc} =$ from user input	= 157.50 [in]
No of anchor bolt	$N_a =$ from user input	= 20
Anchor bolt edge distance	$c_1 = (D_p - D_{bc}) / 2$	= 19.68 [in]
	$c_3 = D_p - c_1$	= 177.18 [in]
	$c_2 = \frac{D_{bc}}{2} \tan \frac{360}{2 N_a}$	= 12.47 [in]
	$c_4 = c_2$	= 12.47 [in]
		ACI 318-19 17.6.2.1.2
Effective embedment depth	$h_{ef}' =$	= 13.12 [in]
Octagon side edge length	$S_p = \frac{D_p}{(1 + \sqrt{2})}$	= 81.54 [in]
Octagon shape conc mat area	$A_p =$	= 32101.5 [in ²]
Projected conc failure area	$A_{NC} = \frac{A_p - (\pi/4) [D_{bc} - \min(3h_{ef}', D_{bc})]^2}{N_a}$	= 1056.9 [in ²]



Single Anchor Bolt Tensile and Shear Load

Factored compression at top of concrete pedestal	$P_u = \frac{M_u}{0.667 D_{bc}} + 0.9 \frac{D_e}{2}$	= 135.54 [kips]	PIP STE03350 -2008 Section 4.6.1 Eq 5
Factored shear at base of vessel	$V_u =$ from user input	= 29.90 [kips]	
Vessel base to concrete support surface friction factor	$\mu =$ from user input	= 0.55	Section 4.6.2
Strength reduction factor	$\phi =$	= 0.75	Section 4.6.2
Factored frictional resistance	$\phi V_f = \phi \mu P_u$	= 55.91 [kips]	Section 4.6.1 Eq 6
	> V_u shear load taken by the friction		Section 4.6.2 Eq 7
Factored <u>single</u> anchor shear load	$V_{ua} =$ shear load taken by the friction	= 0.00 [kips]	

Anchor Tensile - Uplift LCB by Wind

Factored base moment - wind	$M_{uw} =$ from user input	= 1000.9 [kip-ft]	
Vessel empty weight	$D_e =$ from user input	= 47.00 [kips]	
Factored <u>single</u> anchor tensile load	$N_{uaw} = \frac{4 M_{uw}}{N D_e} - 0.9 \frac{D_e}{N}$	= 13.14 [kips]	Section 4.6.1 Eq 4

$$N_a \geq \frac{4 M_{us}}{D_{bc}} \geq 0.9 \frac{D_o}{N_a}$$

Anchor Tensile - Uplift LCB by Seismic

Factored base moment - seismic $M_{us} =$ from user input = 434.20 [kip-ft]
 Vessel operating weight $D_o =$ from user input = 280.80 [kips]

When $\frac{4 M_{us}}{N_a D_{bc}} < 0.9 \frac{D_o}{N_a}$, there is no tensile load mobilized on anchor

Factored single anchor tensile load $N_{uas} = \frac{4 M_{us}}{N_a D_{bc}} - 0.9 \frac{D_o}{N_a} = 0.00$ [kips] Section 4.6.1 Eq 4

Factored single anchor tensile load - max $N_{ua} = \max (N_{uaw}, N_{uas}) = 13.14$ [kips]

Vertical Vessel Anchor Bolt

$P_t = 13.1$ kip $V = 0.0$ kip

Code=ACI 318-19

Result Summary

geometries & weld limitations = **PASS**

limit states max ratio = **0.50 PASS**

Min Anchor Dimensions Check Per PIP STE05121 - Optional

PASS

Min Anchor Dimensions Check

Check min anchor dimensions as per PIP STE05121 Application of ASCE Anchorage Design for Petrochemical Facilities - 2018 Table 1 as shown below.

[This check is NOT a code requirement.](#) User can turn this check On/Off by changing setting at Anchor Bolt --> Anchor Bolt - Config & Setting --> Check min anchor spacing and edge distance as per PIP STE05121 Table 1

Anchor Rod Inputs

Anchor rod grade and dia grade = F1554 Gr36 $d_a = 1.000$ [in]
 Anchor sleeve dia and height $d_s = 3.000$ [in] $h_s = 10.000$ [in]

Min Anchor Edge Distance

Anchor edge distance $c_1 = 19.675$ [in] $c_2 = 12.473$ [in]
 $c_3 = 177.175$ [in] $c_4 = 12.473$ [in]
 Min anchor edge distance required $c_{min} =$ from PIP STE05121 Table 1 below = **5.500** [in] PIP STE05121 Table 1
 Min anchor edge distance $c = \min(c_1, c_2, c_3, c_4) = 19.675$ [in]
 $\geq c_{min}$ OK

Min Anchor Embedment Depth

Min anchor embedment required $h_{min} =$ from PIP STE05121 Table 1 below = **16.000** [in] PIP STE05121 Table 1
 Min anchor embedment depth $h_{ef} =$ from user input = **18.000** [in]
 $\geq h_{min}$ OK

Table 1 from PIP STE05121 Application of ASCE Anchorage Design for Petrochemical Facilities - 2018

PIP STE05121
 Application of ASCE Anchorage Design for Petrochemical Facilities

EDITORIAL REVISION
 January 2018

Table 1 - Minimum Anchor Dimensions – U.S. Customary Units

(See Figure 1 for dimension locations)

R	INAL	IN	PE 2	UT	DF	ASCE ANCHORAGE DESIGN REPORT
						MINIMUM DIMENSIONS (Note 1)

ANCHOR ROD DIAMETER	EFFECTIVE CROSS-SECTIONAL AREA OF ANCHOR ROD TENSION (Note 3)	HEAVY HEX HEAD/ NUT WIDTH	ANCHOR TYPE		h_{ef}	EDGE DISTANCE c_2 (Note 2)		SPACING	SLEEVES (See Note 1 (d))		
			WITH NO AP	WITH AP (Note 4)		A307/A36 F1554 GRADE 36	HIGH-STRENGTH (> 36 ksi) OR TORQUED ANCHORS		SHELL SIZE		h'_e
									Diam d_s	Height h_s	
d_a	$A_{se,N}$	W_h	TB1	TB2	$12d_a$	$4d_a \geq 4.5"$	$6d_a \geq 4.5"$	$4d_a$			
in.	in ²	in.	in.	in.	in.	in.	in.	in.	in.	in.	in.
5/8	0.226	1.25	1.25	--	7.5	4.5	4.5	2.5	2	7	6
3/4	0.334	1.44	1.25	2.25	9.0	4.5	4.5	3.0	2	7	6
7/8	0.462	1.69	1.50	2.50	10.5	4.5	5.3	3.5	2	7	6
1	0.606	1.88	1.75	3.00	12.0	4.5	6.0	4.0	3	10	6
1-1/4	0.969	2.31	2.00	3.50	15.0	5.0	7.5	5.0	--	--	--
1-1/2	1.405	2.75	2.25	4.00	18.0	6.0	9.0	6.0	--	--	--
1-3/4	1.900	3.19	2.50	4.75	21.0	7.0	10.5	7.0	--	--	--
2	2.500	3.63	2.75	5.25	24.0	8.0	12.0	8.0	--	--	--
2-1/4	3.250	4.06	3.00	5.75	27.0	9.0	13.5	9.0	--	--	--
2-1/2	4.000	4.50	3.50	6.50	30.0	10.0	15.0	10.0	--	--	--
2-3/4	4.930	4.94	3.75	7.00	33.0	11.0	16.5	11.0	--	--	--
3	5.970	5.31	4.00	7.75	36.0	12.0	18.0	12.0	--	--	--

NOTES:

1. If sleeves are used, the following dimensional modifications apply:

- (a) Embedment should be the greater of $12d_a$ or $(h_s + h'_e)$
- (b) Edge distance should be increased by $0.5(d_s - d_a)$
- (c) Spacing should be increased by $(d_s - d_a)$
- (d) Partial length sleeves are not recommended for anchors greater than 1 in. See ASCE Anchorage Design Report, Section 3.2.3.1.

Anchor Rod Tensile Resistance		ratio = $13.1 / 26.4$	= 0.50	PASS
Anchor rod effective section area	$A_{se} = 0.61$ [in ²]	$f_{uta} = 58.0$ [ksi]		
Anchor rod steel strength in tension	$N_{sa} = A_{se} f_{uta}$	= 35.15 [kips]		ACI 318-19 17.6.1.2
Max Single Anchor Tensile Force				
Anchor group axial tensile force	$P =$ from user load input	= -13.14 [kips]		in tension
No of anchors in the group	$n_t =$	= 1		
Single anchor tensile force	$T = P / n_t$	= 13.14 [kips]		
Strength reduction factor	$\phi_{ts} = 0.75$			ACI 318-19 17.5.3(a)
	$\phi_{ts} N_{sa} = 0.75 \times 35.15$	= 26.36 [kips]		
	ratio = 0.50	> T		OK

Anchor Concrete Tensile Breakout Resistance		ratio = 13.1 / 35.1	= 0.37	PASS
Anchor embedment depth-adjusted	h_{ef} = from Anchor Forces Calculation above	= 13.117	[in]	
Conc strength & lightweight conc factor	$f_c = 4.4$ [ksi]	$\lambda = 1.0$		ACI 318-19 17.2.4.1
Single anchor concrete breakout strength	$N_b = 24\lambda \sqrt{f_c} h_{ef}^{1.5}$ If $h_{ef} < 11"$ or $h_{ef} > 25"$	= 76.98	[kips]	ACI 318-19 17.6.2.2.1
	$16\lambda \sqrt{f_c} h_{ef}^{5/3}$ If $11" \leq h_{ef} \leq 25"$			ACI 318-19 17.6.2.2.3
Refer to Vertical Vessel Anchor Forces Calculation above for vertical vessel $c_1 \sim c_4$ calculation and design assumptions				
Anchor edge distance	$c_1 = 19.675$ [in]	$c_2 = 12.473$ [in]		
	$c_3 = 177.175$ [in]	$c_4 = 12.473$ [in]		
Anchor out-out spacing	$s_1 = 0.000$ [in]	$s_2 = 0.000$ [in]		
Refer to Vertical Vessel Anchor Forces Calculation above for the details of vertical vessel circular anchor group and single anchor of that group projected failure area A_{NC1} calculation as shown below				
	$A_{NC1} =$	= 1056.9	[in ²]	
	$A_{Nco} = 9 h_{ef}^2$	= 1548.4	[in ²]	ACI 318-19 17.6.2.1.4
No of anchors in the group resisting tension	n_t = from Anchor Forces Calculation above	= 1		
	$A_{Nc} = \min(A_{NC1}, n_t A_{Nco})$	= 1056.9	[in ²]	ACI 318-19 17.6.2.1.1
Eccentricity modification factor	$\Psi_{ec,N}$ = from Anchor Forces Calculation above	= 1.000		ACI 318-19 17.6.2.3.1
Min edge distance	$c_{min} = \min(c_1, c_2, c_3, c_4)$	= 12.473	[in]	
Edge modification factor	$\Psi_{ed,N} = \min[0.7 + \frac{0.3c_{min}}{1.5h_{ef}}, 1.0]$	= 0.890		ACI 318-19 17.6.2.4.1
Conc cracking modification factor	$\Psi_{c,N}$	= 1.00		ACI 318-19 17.6.2.5.1
Conc splitting modification factor	$\Psi_{cp,N}$	= 1.00		ACI 318-19 17.6.2.6.1
Concrete breakout resistance	$N_{cbg} = \frac{A_{Nc}}{A_{Nco}} \Psi_{ec,N} \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,N} N_b$	= 46.78	[kips]	ACI 318-19 17.6.2.1b
Sum of anchors tensile force in anchor group	N_u = from Anchor Forces Calculation above	= 13.14	[kips]	
Strength reduction factor	$\phi_{tc} = 0.75$ supplementary reinfnt present			ACI 318-19 17.5.3(b)
	$\phi_{tc} N_{cbg} = 0.75 \times 46.78$	= 35.08	[kips]	
Seismic design strength reduction	= x 1.0 not applicable	= 35.08	[kips]	ACI 318-19 17.10.5.4(b)
	ratio = 0.37	> N_u		OK

Anchor Pullout Resistance		ratio = 13.1 / 36.6		= 0.36 PASS	
Anchor head net bearing area & conc strength	$A_{brg} = 1.50$ [in ²]	$f_c = 4.4$	[ksi]		
Single bolt pullout resistance	$N_p = 8 A_{brg} f_c$	= 52.23	[kips]	ACI 318-19 17.6.3.2.2a	
Pullout cracking factor	$\Psi_{cP} =$ for cracked concrete	= 1.00		ACI 318-19 17.6.3.3.1(b)	
<hr/>					
Max Single Anchor Tensile Force					
Anchor group axial tensile force	$P =$ from user load input	= -13.14	[kips]	in tension	
No of anchors in the group	$n_t =$	= 1			
Single anchor tensile force	$T = P / n_t$	= 13.14	[kips]		
<hr/>					
Strength reduction factor	$\phi_{tc} = 0.70$	pullout strength is always Condition B		ACI 318-19 17.5.3(c)	
	$\phi_{tc} N_{pn} = \phi_{tc} \Psi_{cP} N_p$	= 36.56	[kips]		
Seismic design strength reduction	= x 1.0 not applicable	= 36.56	[kips]	ACI 318-19 17.10.5.4(c)	
	ratio = 0.36	> T	OK		

Anchor Side Blowout Resistance		N/A	
Anchor Inputs			
Anchor edge distance	$c_1 = 19.675$ [in]	$c_2 = 12.473$ [in]	<p style="text-align: center;">$P + V_y + M_x$</p>
	$c_3 = 177.175$ [in]	$c_4 = 12.473$ [in]	
Anchor out-out spacing	$s_1 = 0.000$ [in]	$s_2 = 0.000$ [in]	
Anchor edge distance - min	$c_{a1} = \min(c_1, c_2, c_3, c_4)$	= 12.473	[in]
Anchor embedment depth	$h_{ef} =$ from user input	= 18.000	[in]
Side blowout check is required on this edge or not	= check if $h_{ef} > 2.5 c_{a1}$	= False	ACI 318-19 17.6.4.1
	Side blowout check is NOT required		ACI 318-19 17.6.4.1

Anchor Group Governing Tensile Resistance			
Anchor group governing tensile resistance is the minimum value of the resistance values in the following limit states			
No of anchors in anchor group resisting tension	$n_t =$ from Anchor Forces Calculation above	= 1	
Anchor rod tensile resistance	$n_t \phi N_{sa} = 1 \times 26.36$	= 26.36	[kips]
Anchor concrete breakout resistance	$\phi N_{cbg} =$ from anchor conc breakout calc above	= 35.08	[kips]
Anchor pullout resistance	$n_t \phi N_{pm} = 1 \times 36.56$	= 36.56	[kips]
Anchor side blowout resistance	$\phi N_{sbg} =$ from anchor side blowout calc above	= N/A	
Anchor group governing tensile resistance	$\phi N_n =$ minimum of above values	= 26.36	[kips]

Anchor Shear Resistance and Tension - Shear Interaction**N/A**

There is no shear load from user load input or shear key is used and all shear is taken by shear key, so Anchor Shear Resistance and Tension - Shear Interaction checks are Not Applicable

Anchor Seismic Design**N/A****Seismic - Tension** Not Applicable

ACI 318-19 17.10.5.1

Seismic SDC < C or E $\leq 0.2U$, additional seismic requirements in ACI 318-19 17.10.5.3 is NOT required

ACI 318-19 17.10.5.3

Seismic - Shear Not Applicable

ACI 318-19 17.10.6.1

There is no shear load applied to anchor/anchor group, so Seismic Shear check is NOT required